

2021 to 2024

**Q40011911 - Is this possible with the ARC-9200
and if it is possible to send signal by protocol
Modbus TCP/IP to SNMP server in case of
failure”?**

All our controllers do not support Modbus protocol.

Unique solution ID: #1826

Author: Simone

Last update: 2020-08-25 11:10