

**2016 to 2020**

**Q60011911 - Is this possible with the ARC-9200  
and if it is possible to send signal by protocol  
Modbus TCP/IP to SNMP server in case of  
failure”?**

All our controllers do not support Modbus protocol.

Unique solution ID: #1849

Author: Simone

Last update: 2020-08-26 05:07