

**2019**

**Q40011911 - Is this possible with the ARC-9200  
and if it is possible to send signal by protocol  
Modbus TCP/IP to SNMP server in case of  
failure”?**

All our controllers do not support Modbus protocol.

Unique solution ID: #1876

Author: Simone

Last update: 2019-11-19 10:09